



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
 Opp. Muthu Mandapam, Old Katpadi Road, Vellore.632 004
 Phone: 0416-2215168. E-Mail: twadlabphotos2021@gmail.com



TC - 16337

TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Report No.	TR/2026/67945	Report Issue Date	28.09.2026	Page No: 01 of 02
Invoice Details	11871/ dt:25.09.2026	ULR. No.	TC16337260000000045F	

Client Name & Address Contact No./Email.ID	:	Bharathidhasanar Public School, Cheyyar to Arni Road, Perumpallam Village, Cheyyar Taluk, Thiruvannamalai District-604407.		
Sample Submitted by	:	Babu		
Sample Location	:	Bharathidhasanar Public School		
Sample Description	:	Clear Colorless Liquid		
Sample Name	:	Water	Sample Source	: Bore well
Sample/Lab No.	:	2026/67945	Sample Container	: Plastic – Good
Quantity of sample Received	:	2 lit	Sample Condition	: Good
Sample Received on	:	25.09.2026	Temperature / Humidity %	: 25°C / 50%
Test Commenced on	:	25.09.2026	Test Completed on	: 26.09.2026

S. No	Parameters	Test Method	Unit	Result (2026/67945)	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Colour	IS3025:Part4: 2021	Hazen	<1	5	15
2	Odour	IS3025:Part5: 2018	–	Agreeable	Agreeable	Agreeable
3	Taste	IS3025:Part8: 2023	–	Agreeable	Agreeable	Agreeable
4	Turbidity	IS3025:Part10: 2023	NTU	< 0.5	1	5
5	pH@25°C	IS3025: Part11: 2022	–	6.66	6.5-8.5	No Relaxation
6	Total Dissolved Solids	IS3025:Part16: 2023	mg/L	77	500	2000
7	Total Alkalinity as CaCO ₃	IS3025: Part23: 2023	mg/L	24	200	600
8	Total Hardness as CaCO ₃	IS3025: Part21:2009 (RA:2023)	mg/L	42	200	600
9	Calcium as Ca	IS3025:Part40: 2024	mg/L	9	75	200
10	Magnesium as Mg	IS3025:Part46: 2023	mg/L	5	30	100
11	Chloride as Cl	IS3025:Part32: 1988(RA:2019)	mg/L	15	250	1000
12	Nitrate as NO ₃	APHA 24 th Edn – 4500 – NO ₃ – B – 2023 (Screening Method)	mg/L	<0.2	45	No Relaxation
13	Fluoride as F	APHA 24 th Edn – 4500 – F – D – 2023 (Spadns Method)	mg/L	<0.2	1.0	1.5
14	Sulphate as SO ₄	APHA 24 th Edn – 4500 – SO ₄ – E – 2023 (Turbidimetric Method)	mg/L	8	200	400

Remark: The sample is conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Physical & Chemical.

The test results relate only to the items tested.

The result applied to the sample as received basis.

The test items will not be retained for more than 15 days from the date of issue of the test report

BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe)

The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

.....End of the Report.....

B. S. Narendiran
 Authorized Signatory
 M.S. NARENDIRAN, M.Sc
 Junior Water Analyst
 DWTL - Vellore

Issue No./Date	01/10.01.2021	Amend. No./Date	01/02.01.2026	Page No.	1 of 2
----------------	---------------	-----------------	---------------	----------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Opp. Muthu Mandapam, Old Katpadi Road, Vellore.632 004

Phone: 0416-2215168. E-Mail: twadlabphotos2021@gmail.com

TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Report No.	TR/2026/67945A	Report Issue Date	28.09.2026	Page No: 02 of 02
Invoice Details	11871 dt:25.09.2026			

S. No	Parameters	Test Method	Unit	Result (2026/67945 A)	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	P. Alkalinity as CaCO ₃	IS3025:Part23: 2023	mg/L	Zero	--	--
2	Manganese as Mn	IS3025(Part59) : 2023	mg/L	0.0	0.1	0.3
3	Ammonia as NH ₃ -N	IS3025(Part34) : 2019	mg/L	0.0	0.5	No relaxation
4	Nitrite as NO ₂	IS3025(Part34/Sec-1) :2023	mg/L	0.0	--	--
5	Iron	APHA 23rd Edition 2017-3500 Fe B	mg/L	0.0	0.3	1.0
6	Phosphate as PO ₄	IS3025(Part31/Sec-1) :2022	mg/L	0.0	0.0	0.0
7	Residual Chlorine	IS/APHA	mg/L	0.0	0.2	1.0

Bacteriological Test

1	Total Coliform	IS 15185: 2016 (RA: 2021)	CFU	Absence	Absence / 100 mL
2	Fecal Coliform	IS 15185: 2016 (RA: 2021)	CFU	Absence	Absence / 100 mL

Remark:

- The Tested sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Chemical.
- The Tested sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Bacteriological.

The test results relate only to the items tested.

The result applied to the sample as received basis.

The test items will not be retained for more than 15 days from the date of issue of the test report

BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe)

The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

.....End of the Report.....

6.5.46m-192/28/9/26
Authorized Signatory

M.S. NARENDIRAN, M.Sc

Junior Water Analyst

DWTL - Vellore

Issue No./Date	01/10.01.2021	Amend. No./Date	01/02.01.2026	Page No.	2 of 2
----------------	---------------	-----------------	---------------	----------	--------



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TVM52073

Issued Date : 12-09-2026

Organization Type : Educational Institutions

Expiry Date : 11-09-2027

Name of the Organization : BHARATHIDHASANAR PUBLIC SCHOOL

Address : CHEYYAR TO ARANI ROAD, PERUMPALLAM VILLAGE,
CHEYYAR TALUK, TIRUVANNAMALAI DISTRICT, TAMILNADU,
PIN - 604407

I, V KAVITHA owner/manager of the BHARATHIDHASANAR PUBLIC SCHOOL functioning as Educational Institutions located at Perumpallam in Tiruvannamalai district hereby declare that

- This Self-Declared Sanitation certificate is valid from 12-09-2026 to 11-09-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 850 people/pupils and has 43 urinals and 28 toilets which is proportionate to the number of users as per government norms.
- 5 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00126TVM52073 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TVM52073 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.